

NOTIFIED BODY No. 1396 Osloboditeľov 282, 059 35 Batizovce, Slovakia

tel. +421 52 7752298 fax. +421 52 7881412 http://www.fires.sk



## Certificate of constancy of performance

## 1396-CPR-0116

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

## Ejection natural smoke and heat exhaust ventilator, type DSC-C and DSF DU6

a dual purpose smoke and heat exhaust ventilator type B – device for the movement of hot gases out of the construction works which has provision to allow its use for comfort ventilation, used on conditions described in the Assessment and verification of constancy of performance No. C1396/16/0014/4003/SC issued by FIRES, s.r.o., Notified Body 1396 on 19. 08. 2016 and an actual report of continuous surveillance

placed on the market under the name or trade mark of

FAKRO PP Sp. z o.o. Wegierska 144a, 33-300 Nowy Sacz, Poland

and produced in the manufacturing plant

FAKRO PP Sp. z o.o. Wegierska 144a, 33-300 Nowy Sacz, Poland

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 12101-2: 2003

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

## constancy of performance of the construction product.

This certificate was first issued on 19.08.2016 and will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The Experts on Fire Safety

Batizovce, 19. 08. 2016

Ing. Mária Gašperová

Head of Product Certification Body

074015

FIRES 136a/C-12/01/2016-E